

# TECHNICAL REPORT

# IEC TR 60071-4

First edition  
2004-06

---

---

## Insulation co-ordination –

### Part 4: Computational guide to insulation co-ordination and modelling of electrical networks

© IEC 2004 — Copyright - all rights reserved

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission, 3, rue de Varembé, PO Box 131, CH-1211 Geneva 20, Switzerland  
Telephone: +41 22 919 02 11 Telefax: +41 22 919 03 00 E-mail: [inmail@iec.ch](mailto:inmail@iec.ch) Web: [www.iec.ch](http://www.iec.ch)



Commission Electrotechnique Internationale  
International Electrotechnical Commission  
Международная Электротехническая Комиссия

PRICE CODE **XE**

*For price, see current catalogue*

## CONTENTS

FOREWORD.....	7
1 Scope and object.....	9
2 Normative references.....	9
3 Terms and definitions .....	9
4 List of symbols and acronyms .....	12
5 Types of overvoltages.....	12
6 Types of studies .....	13
6.1 Temporary overvoltages (TOV).....	14
6.2 Slow-front overvoltages (SFO).....	14
6.3 Fast-front overvoltages (FFO).....	15
6.4 Very-fast-front overvoltages (VFFO).....	15
7 Representation of network components and numerical considerations .....	15
7.1 General .....	15
7.2 Numerical considerations.....	15
7.3 Representation of overhead lines and underground cables .....	18
7.4 Representation of network components when computing temporary overvoltages .....	19
7.5 Representation of network components when computing slow-front overvoltages .....	25
7.6 Representation of network components when computing fast-front transients .....	30
7.7 Representation of network components when computing very-fast-front overvoltages .....	42
8 Temporary overvoltages analysis .....	44
8.1 General .....	44
8.2 Fast estimate of temporary overvoltages .....	45
8.3 Detailed calculation of temporary overvoltages [2], [9] .....	45
9 Slow-front overvoltages analysis .....	48
9.1 General .....	48
9.2 Fast methodology to conduct SFO studies .....	48
9.3 Method to be employed.....	49
9.4 Guideline to conduct detailed statistical methods .....	49
10 Fast-front overvoltages analysis.....	52
10.1 General .....	52
10.2 Guideline to apply statistical and semi-statistical methods.....	53
11 Very-fast-front overvoltage analysis .....	58
11.1 General .....	58
11.2 Goal of the studies to be performed .....	58
11.3 Origin and typology of VFFO .....	58
11.4 Guideline to perform studies .....	60
12 Test cases.....	60
12.1 General .....	60
12.2 Case 1: TOV on a large transmission system including long lines .....	60
12.3 Case 2 (SFO) – Energization of a 500 kV line .....	68
12.4 Case 3 (FFO) – Lightning protection of a 500 kV GIS substation .....	73
12.5 Case 4 (VFFO) – Simulation of transients in a 765 kV GIS [51] .....	80

Annex A (informative) Representation of overhead lines and underground cables .....	86
Annex B (informative) Arc modelling: the physics of the circuit-breaker .....	90
Annex C (informative) Probabilistic methods for computing lightning-related risk of failure of power system apparatus .....	93
Annex D (informative) Test case 5 (TOV) – Resonance between a line and a reactor in a 400/220 kV transmission system .....	99
Annex E (informative) Test case 6 (SFO) – Evaluation of the risk of failure of a gas-insulated line due to SFO .....	105
Annex F (informative) Test case 7 (FFO) – High-frequency arc extinction when switching a reactor .....	113
Bibliography .....	116
Figure 1 – Types of overvoltages (excepted very-fast-front overvoltages).....	12
Figure 2 – Damping resistor applied to an inductance .....	17
Figure 3 – Damping resistor applied to a capacitance .....	17
Figure 4 – Example of assumption for the steady-state calculation of a non-linear element.....	17
Figure 5 – AC-voltage equivalent circuit.....	19
Figure 6 – Dynamic source modelling .....	20
Figure 7 – Linear network equivalent .....	21
Figure 8 – Representation of load in [56] .....	24
Figure 9 – Representation of the synchronous machine .....	26
Figure 10 – Diagram showing double distribution used for statistical switches .....	29
Figure 11 – Multi-story transmission tower [16], $H = l_1 + l_2 + l_3 + l_4$ .....	31
Figure 12 – Example of a corona branch model .....	33
Figure 13 – Example of volt-time curve.....	34
Figure 14 – Double ramp shape.....	38
Figure 15 – CIGRE concave shape .....	39
Figure 16 – Simplified model of earthing electrode.....	41
Figure 17 – Example of a one-substation-deep network modelling .....	51
Figure 18 – Example of a two-substation-deep network modelling.....	51
Figure 19 – Application of statistical or semi-statistical methods .....	53
Figure 20 – Application of the electro-geometric model.....	56
Figure 21 – Limit function for the two random variables considered: the maximum value of the lightning current and the disruptive voltage .....	57
Figure 22 – At the GIS-air interface: coupling between enclosure and earth ( $Z_3$ ), between overhead line and earth ( $Z_2$ ) and between bus conductor and enclosure ( $Z_1$ ) [33] .....	59
Figure 23 – Single-line diagram of the test-case system .....	62
Figure 24 – TOV at CHM7, LVD7 and CHE7 from system transient stability simulation.....	63
Figure 25 – Generator frequencies at generating centres Nos. 1, 2 and 3 from system transient stability simulation .....	64
Figure 26 – Block diagram of dynamic source model [55].....	65
Figure 27 – TOV at LVD7 – Electromagnetic transient simulation with 588 kV and 612 kV permanent surge arresters.....	66

Figure 28 – TOV at CHM7 – Electromagnetic transient simulation with 588 kV and 612 kV permanent surge arresters.....	67
Figure 29 – TOV at LVD7 – Electromagnetic transient simulation with 484 kV switched metal-oxide surge arresters.....	67
Figure 30 – TOV at CHM7 – Electromagnetic transient simulation with 484 kV switched metal-oxide surge arresters.....	67
Figure 31 – Representation of the system.....	68
Figure 32 – Auxiliary contact and main .....	70
Figure 33 – An example of cumulative probability function of phase-to-earth overvoltages and of discharge probability of insulation in a configuration with trapped charges and insertion resistors.....	72
Figure 34 – Number of failure for 1 000 operations versus the withstand voltage of the insulation .....	72
Figure 35 – Schematic diagram of a 500 kV GIS substation intended for lightning studies.....	74
Figure 36 – Waveshape of the lightning stroke current.....	75
Figure 37 – Response surface approximation (failure and safe-state representation for one GIS section (node)) .....	77
Figure 38 – Limit-state representation in the probability space of the physical variables Risk evaluation .....	79
Figure 39 – Single-line diagram of a 765 kV GIS with a closing disconnecter .....	81
Figure 40 – Simulation scheme of the 765 kV GIS part involved in the transient phenomena of interest.....	81
Figure 41 – 4 ns ramp .....	84
Figure 42 – Switch operation .....	85
Figure A.1 – Pi-model.....	86
Figure A.2 – Representation of the single conductor line.....	87
Figure B.1 – SF <sub>6</sub> circuit-breaker switching .....	91
Figure C.1 – Example of a failure domain .....	96
Figure D.1 – The line and the reactance are energized at the same time.....	99
Figure D.2 – Energization configuration of the line minimizing the risk of temporary overvoltage .....	100
Figure D.3 – Malfunction of a circuit-breaker pole during energization of a transformer .....	102
Figure D.4 – Voltage in substation B phase A whose pole has not closed.....	103
Figure D.5 – Voltage in substation B phase B whose pole closed correctly .....	103
Figure D.6 – Voltage in substation B phase A where the breaker failed to close (configuration of Figure D.2).....	104
Figure E.1 – Electric circuit used to perform closing overvoltage calculations .....	105
Figure E.2 – Calculated overvoltage distribution – Two estimated Gauss probability functions resulting from two different fitting criteria (the $U_{2\%}$ and $U_{10\%}$ guarantees a good fitting of the most dangerous overvoltages).....	107
Figure E.3 – Example of switching overvoltage between phases A and B .....	109
Figure E.4 – Voltage distribution along the GIL (ER-energization ED-energization under single-phase fault ChPg-trapped charges) .....	110
Figure F.1 – Test circuit (Copyright1998 IEEE [48]) .....	113
Figure F.2 – Terminal voltage and current of GCB model (Copyright 1998 IEEE [48]).....	113
Figure F.3 – Measured arc parameter (Copyright 1998 IEEE [48]).....	114

Figure F.4 – Circuit used for simulation .....	114
Figure F.5 – Comparison between measured and calculated results (Copyright 1998 IEEE [48]) .....	115
Table 1 – Classes and shapes of overvoltages – Standard voltage shapes and standard withstand tests .....	13
Table 2 – Correspondence between events and most critical types of overvoltages generated .....	14
Table 3 – Application and limitation of current overhead line and underground cable models .....	18
Table 4 – Values of $U_0$ , $k$ , $DE$ for different configurations proposed by [59] .....	35
Table 5 – Minimum transformer capacitance to earth taken from [44] .....	37
Table 6 – Typical transformer capacitance to earth taken from [28] .....	37
Table 7 – Circuit-breaker capacitance to earth taken from [28] .....	37
Table 8 – Representation of the first negative downward strokes .....	40
Table 9 – Time to half-value of the first negative downward strokes .....	40
Table 10 – Representation of the negative downward subsequent strokes .....	40
Table 11 – Time to half-value of negative downward subsequent strokes .....	40
Table 12 – Representation of components in VFFO studies .....	43
Table 13 – Types of approach to perform FFO studies .....	52
Table 14 – Source side parameters .....	69
Table 15 – Characteristics of the surge arresters .....	69
Table 16 – Characteristics of the shunt reactor .....	69
Table 17 – Capacitance of circuit-breaker .....	70
Table 18 – Trapped charges .....	70
Table 19 – System configurations .....	71
Table 20 – Recorded overvoltages .....	71
Table 21 – Number of failures for 1 000 operations .....	72
Table 22 – Modelling of the system .....	76
Table 23 – Data used for the application of the EGM .....	76
Table 24 – Crest-current distribution .....	77
Table 25 – Number of strikes terminating on the different sections of the two incoming overhead transmission lines .....	77
Table 26 – Parameters of GIS disruptive voltage distribution and lightning crest-current distribution .....	78
Table 27 – FORM risk estimations (tower footing resistance = 10 $\Omega$ ) .....	79
Table 28 – Failure rate estimation for the GIS11 .....	80
Table 29 – Representation of GIS components – Data of the 765 kV GIS .....	82
Table D.1 – Line parameters .....	100
Table D.2 – 400 /220/33 kV transformer .....	101
Table D.3 – 220 /13,8 kV transformer .....	101
Table D.4 – Points of current and flux of 400 /220/33 kV transformer .....	101
Table D.5 – Points of current and flux of 220 /13,8 kV transformer .....	101
Table D.6 – Points of current and flux of 400 kV /150 MVA .....	102
Table E.1 – Parameters of the power supply .....	105

Table E.2 – Standard deviation and $U_{50M}$ for different lengths (SIWV = 1 050 kV).....	108
Table E.3 – Standard deviation and $U_{50M}$ for different lengths (SIWV = 950 kV).....	108
Table E.4 – Standard deviation and $U_{50M}$ for different lengths (SIWV = 850 kV).....	108
Table E.5 – Statistical overvoltages $U_{2\%}$ and $U_{10\%}$ for every considered configuration .....	110
Table E.6 – Risks for every considered configuration.....	111
Table E.7 – Number of dielectric breakdowns over 20 000 operations for every configuration .....	112

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

---

**INSULATION CO-ORDINATION –****Part 4: Computational guide to insulation co-ordination  
and modelling of electrical networks**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC 60071-4, which is a technical report, has been prepared by IEC technical committee 28: Insulation co-ordination.

The text of this technical report is based on the following documents:

Enquiry draft	Report on voting
28/156/DTR	28/158/RVC

Full information on the voting for the approval of this technical report can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- transformed into an International standard
- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

A bilingual version of this technical report may be issued at a later date.



## INSULATION CO-ORDINATION –

### Part 4: Computational guide to insulation co-ordination and modelling of electrical networks

#### 1 Scope and object

This technical report gives guidance on conducting insulation co-ordination studies which propose internationally recognized recommendations

- for the numerical modelling of electrical systems, and
- for the implementation of deterministic and probabilistic methods adapted to the use of numerical programmes.

Its object is to give information in terms of methods, modelling and examples, allowing for the application of the approaches presented in IEC 60071-2, and for the selection of insulation levels of equipment or installations, as defined in IEC 60071-1.

#### 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60060-1:1989, *High-voltage test techniques – Part 1: General definitions and test requirements*

IEC 60071-1:1993, *Insulation co-ordination – Part 1: Definitions, principles and rules*

IEC 60071-2:1996, *Insulation co-ordination – Part 2: Application guide*

IEC 60076-8:1997, *Power transformers – Part 8: Application guide*

IEC 60099-4:1991, *Surge arresters – Part 4: Metal-oxide surge arresters without gaps for a.c. systems*<sup>1</sup>

IEC 61233:1994, *High-voltage alternating current circuit-breakers – Inductive load switching*

---

<sup>1</sup> A consolidated edition exists, published in 2001, which incorporates the current edition, plus its amendment 1 (1998) and amendment 2 (2001).